



# MANUFACTURERS CERTIFICATION

## ENVIRONMENTAL MANAGEMENT AUSTRALASIA

The following Morgan Ceramic Tile Adhesive product has been assessed to the SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT RULE 1168 and certified in our laboratory under the Environmental Management Australasia system to release volatile organic levels (VOC's) of less than 65g/L -

**Flexmaster**  
**VOC internal method**  
**< 15 gram per Litre**